



Test Results for High/Flash fire:

Parallel Position Clearance Distance	Position	Clearance (mm)	Max temp rise (°C)	
			High	Flash
	(A) Rear	140	Rear Wall	
			41.29	49.49
	(B) Side	250	Side Wall	
			47	59.12
	(C) Floor protector (front)	300	Floor	
			20.21	23.56
	(D) Floor protector (side)	200	Ceiling	
			32.08	38.31

Corner Position Clearance Distance	Position	Clearance (mm)	Max temp rise (°C)	
			High	Flash
	(F) Side	100	Rear Wall	
			45.93	49.35
	(G) Side	100	Side Wall	
			49.23	51.33
	(H) Floor protector (front)	300	Floor	
			24.28	23.56
	(I) Floor protector (side)	200	Ceiling	
			46.33	49.41

* Note that this temperature passed within the laboratories margin of uncertainty.

Technical Note:

1. The clearance measurement A, B, F and G were taken from the distance between walls and closest point of the appliance, C and H were measured from the front of the fuel-loading opening to the edge of the floor protector, D and I were measured from each side of fuel-loading opening.
2. The flue was installed onto the flue spigot, extended centrally and vertically without bend before and after penetration of the ceiling plane.
3. Drawings shown above are not to scale.